



POWERTECHNIC (HONG KONG) LIMITED

香港九龍佐敦茂林街 16-18 號茂林商業大廈 11 樓
11/F, Mau Lam Commercial Building
16-18 Mau Lam Street, Jordan, Hong Kong

Tel : (852) 2342 8077 Fax : (852) 2342 1077
Web : www.powertechnic.com

ENERGY SAVING REPORT

Fluorescent Lamp with Electromagnetic Ballast

Customer Name	DHL	Customer No	HK2241
Address	赤鱘角駿運路 2 號機場空運中心商業大樓 7 樓		

Item	Equipment	Model No.	Quantity	Installation MCB
1	kWh Meter	-	1	DB HRC,R6,R12
2	Hourly Meter	H37	1	DB HRC,R6,R12
3	TubeSaver	TST5 28W	16	DB HRC,R6,R12

Without SAVING SYSTEM	START	END
Date	15-Aug-08	5-Sep-08
kWh Meter Reading	0.10	321.10
Hourly Meter Reading	0.00	499.05
Recording time	15:46	10:50

With TubeSaver SAVING SYSTEM	START	END
Date	5-Sep-08	26-Sep-08
kWh Meter Reading	322.90	508.10
Hourly Meter Reading	503.22	1003.70
Recording time	15:00	11:25

Comparison	Accumulated Time (hr)	Power Consumption (kWh)	Hourly Power Consumption (kWh)	Saving Rate
Without SAVING SYSTEM	499.05	321.00	0.6432(0.0402/unit)	42.50%
With SAVING SYSTEM	500.48	185.20	0.37(0.0231/unit)	

<p>SIGNED ON BEHALF OF CUSTOMER</p>   <p>Date _____</p> <p>SIGNATURE & COMPANY STAMP</p>	<p>SIGNED ON BEHALF OF POWERTECHNIC (HONG KONG) LTD</p>   <p>Date <u>2-Oct-08</u></p> <p>SIGNATURE & COMPANY STAMP</p>
--	---