



香港九龍佐敦茂林街 16-18 號茂林商業大廈 11 樓  
11/F, Mau Lam Commercial Building  
16-18 Mau Lam Street, Jordan, Hong Kong

Tel: (852) 2342 8077 Fax: (852) 2342 1077  
Web : www.powertechnic.com

### ENERGY SAVING REPORT

#### Fluorescent Lamp with Electromagnetic Ballast

Customer Name	Citi Group	Customer No	HK2167
Address	Two Harbourfront 9th Floor		

Item	Equipment	Model No.	Quantity	Installation MCB
1	kWh Meter	-	2	9NL-10R-10Y-13B-13Y
2	Hourly Meter	-	2	9NL-10R-10Y-13B-13Y
3	TubeSaver	TST5 28W	44	9NL-10R-10Y-13B-13Y
4	T8 With E.B	2-Foot T8	53	9NL-10R-10Y-13B-13Y

Without SAVING SYSTEM	START	END
Date	1-Dec-07	12-Jan-08
kWh Meter Reading	0.70	675.00
Hourly Meter Reading	0.24	565.60
Recording time	16:00p.m	10:54a.m

With TubeSaver SAVING SYSTEM	START	END
Date	1-Dec-07	12-Jan-08
kWh Meter Reading	0.70	318.90
Hourly Meter Reading	0.23	564.97
Recording time	16:00p.m	10:54a.m

Comparision	Accumulated Time (hr)	Power Consumption (kWh)	Hourly Power Consumption	Saving Rate
Without SAVING SYSTEM	565.84	674.30	1.19(0.0225/unit)	56.40%
With SAVING SYSTEM	564.7	318.2	0.56(0.0127/unit)	

SIGNED ON BEHALF OF CUSTOMER  Date <u>16/1/08</u> SIGNATURE & COMPANY STAMP 	SIGNED ON BEHALF OF POWERTECHNIC (HONG KONG) LTD   Date <u>15-1-08</u> SIGNATURE & COMPANY STAMP
--	---