



**POWERTECHNIC (HONG KONG) LIMITED**

香港九龍佐敦茂林街 16-18 號茂林商業大廈 11 樓  
11/F, Mau Lam Commercial Building  
16-18 Mau Lam Street, Jordan, Hong Kong

Tel : (852) 2342 8077 Fax : (852) 2342 1077  
Web : www.powertechnic.com

**ENERGY SAVING REPORT**

**Fluorescent Lamp with Magnetic Ballast**

<b>Customer Name</b>	JPMorgan Chase Bank,N.A	<b>Customer No</b>	HK2372
<b>Address</b>	18/F, JPMorgan Tower, 138 Shatin Rural Committee Road, Shatin, New Territories		

Item	Equipment	Model No.	Quantity	Installation MCB
1	METER	DD28(2207-08128214)	1	18L2"Y4
2	HOUR METER	206	1	18L2"Y4
3	T8/18W Fluorescent tube	-	58	18L2"b2,b3
4	TubeSaver T5	TST5/14W/840E	21	18L2"Y4

Without SAVING SYSTEM	START	END
Date	27-Sep-08	4-Oct-08
kWh Meter Reading	0.90	112.20
Hourly Meter Reading	0.50	70.04
Recording time	11:10	10:05

With SAVING SYSTEM	START	END
Date	4-Oct-08	11-Oct-08
kWh Meter Reading	0.80	16.90
Hourly Meter Reading	2904.02	2964.96
Recording time	12:20	10:18

Comparision	Accumulated Time (hr)	Power Consumption (kWh)	Hourly Power Consumption (kWh)	Saving Rate
Without SAVING SYSTEM	69.5	111.3	1.601(0.0276/Unit)	54.7%
With SAVING SYSTEM	60.9	16.1	0.264(0.0125/Unit)	

<p>SIGNED ON BEHALF OF CUSTOMER</p>   <p>Date _____</p> <p>SIGNATURE &amp; COMPANY STAMP</p>	<p>SIGNED ON BEHALF OF POWERTECHNIC (HONG KONG) LTD</p>   <p>Date 15-Oct-08</p> <p>SIGNATURE &amp; COMPANY STAMP</p>
--	---