



POWERTECHNIC (HONG KONG) LIMITED

香港九龍佐敦茂林街 16 -18 號茂林商業大廈 11 樓
11/F, Mau Lam Commercial Building
16 -18 Mau Lam Street, Jordan, Hong Kong

Tel: (852) 2342 8077 Fax: (852) 2342 1077
Web : www.powertechnic.com

ENERGY SAVING REPORT

Customer Name	CENTALINE PROPERTY AGENCY LTD	Customer No	HK2234
Address	5/F TOWER 1, NEW WORLD TOWER ,18 QUEEN'S CENTRAL HONG KONG		

Item	Equipment	Model No.	Serial No.	Installation MCB
1	KWh Meter	3P40A	2007-08109168	/
2	Hourly Meter	/	3.240.201.075	/
3	TubeSaver	TST5/28W x 18nos	/	/

Without SAVING SYSTEM	START	END
Date	22-Nov-07	10-Nov-07
kWh Meter Reading	0.3	111.5
Hourly Meter Reading	1247.78	1398.45
Recording time	8:20 PM	1:10 PM

With SAVING SYSTEM	START	END
Date	10-Nov-07	28-Nov-07
kWh Meter Reading	111.7	175.9
Hourly Meter Reading	1399.5	1564.19
Recording time	1:38 PM	3:05 PM

Comparison	Accumulated Time (hr)	Power Consumption (kWh)	Hourly Power Consumption (kWh)	Saving Rate
Without SAVING SYSTEM	150.67	111.2	0.74	47.3%
With SAVING SYSTEM	164.69	64.2	0.39	

<p>SIGNED ON BEHALF OF CUSTOMER</p>   <p>Date <u>14 Feb 08</u></p>	<p>SIGNED ON BEHALF OF POWERTECHNIC (HONG KONG) LTD</p>  <p><i>kkk</i></p> <p>Date <u>31 DEC 2007</u></p>
SIGNATURE & COMPANY STAMP	SIGNATURE & COMPANY STAMP

Testing for lighting