



香港九龍佐敦茂林街 16-18 號茂林商業大廈 11 樓
11/F, Mau Lam Commercial Building
16-18 Mau Lam Street, Jordan, Hong Kong

Tel : (852) 2342 8077 Fax : (852) 2342 1077
Web : www.powertechnic.com

ENERGY SAVING REPORT

Fluorescent Lamp with Electromagnetic Ballast

Customer Name	Hong Kong Housing Society	Customer No	HK2211
Address	Mountain Shore. 8 Yuk Tai Street, Ma On Shan.		


Item	Equipment	Model No.	Quantity	Installation MCB
1	KWh METER	SP40A	1	DB-GDA
2	TubeSaver	TST5 / 28W	10	DB-GDA
3				
4				

Without SAVING SYSTEM	START	END
Date	20-Jul-07	27-Jul-07
kWh Meter Reading	2.9	80.4
Hourly Meter Reading	2943.67	3110.52
Recording time	5:09 PM	4:02 PM

With SAVING SYSTEM	START	END
Date	13-Aug-07	30-Aug-07
kWh Meter Reading	220.4	312.4
Hourly Meter Reading	3519.21	3926.13
Recording time	4:53 PM	3:49 PM

Comparison	Accumulated Time (hr)	Power Consumption (kWh)	Hourly Power Consumption (kWh)	Saving Rate
Without SAVING SYSTEM	166.85	77.5	0.46	51%
With SAVING SYSTEM	406.92	92.0	0.23	


SIGNED ON BEHALF OF CUSTOMER



Date 31/8/07

SIGNATURE & COMPANY STAMP

SIGNED ON BEHALF OF POWERTECHNIC (HONG KONG) LTD



Date 30 AUG 2007

SIGNATURE & COMPANY STAMP