



POWERTECHNIC (HONG KONG) LIMITED

香港九龍佐敦茂林街 16-18 號茂林商業大廈 11 樓
11/F, Mau Lam Commercial Building
16-18 Mau Lam Street, Jordan, Hong Kong

Tel: (852) 2342 8077 Fax: (852) 2342 1077
Web: www.powertechnic.com

ENERGY SAVING REPORT



Customer Name	YIP'S CHEMICAL HOLDINGS LIMITED	Customer No	HK2154
Address	Yip's Hang Cheung Bldg., 13 yip Cheong St. On Lok Tsuen, Fanling, N.T. Hong Kong		

Item	Equipment	Model No.	Serial No.	Installation MCB
1	DR. LIGHT	DL120	120S10068	
2	kWh METER	SP40AMP	2005-114086	

Without SAVING SYSTEM	START	END
Date	1-Apr-06	8-Apr-06
kWh Meter Reading	1113.6	1256.3
Hourly Meter Reading	645.22	757.86
Recording time	12:45 PM	10:00 AM

With SAVING SYSTEM	START	END
Date	8-Apr-06	20-Apr-06
kWh Meter Reading	1256.3	1426.7
Hourly Meter Reading	757.91	955.7
Recording time	10:04 AM	10:05 AM

Comparison	Accumulated Time (hr)	Power Consumption (kWh)	Hourly Power Consumption	Saving Rate
Without SAVING SYSTEM	112.64	143	1.27	32.0%
With SAVING SYSTEM	187.79	170	0.86	

SIGNED ON BEHALF OF CUSTOMER   Date <u>26-4-2006</u>	SIGNED ON BEHALF OF POWERTECHNIC (HONG KONG) LTD   Date <u>21/4/06</u>
SIGNATURE & COMPANY STAMP	SIGNATURE & COMPANY STAMP