



ENERGY SAVING REPORT

Fluorescent Lamp with Electromagnetic Ballast

Customer Name	Roy Mark	Customer No	HK2100
Address	柴灣利眾街34號寶源工業大廈5樓		

Item	Equipment	Model No.	Quantity	Installation MCB
1	KWh METER	2007-08129252	1-no.	AC-Y2
2	HOURLY METER	-	1-no.	AC-Y2
3	T5	TST5/ 28W	15-sets	-
4				

Without SAVING SYSTEM	START	END
Date	28 Feb., 2008	13 March, 2008
kWh Meter Reading	0.1	104.8
Hourly Meter Reading	0.16	158.19
Recording time	7:30 PM	10:38 AM

With SAVING SYSTEM	START	END
Date	13 March, 2008	29 March, 2008
kWh Meter Reading	105.1	156.6
Hourly Meter Reading	158.87	311.75
Recording time	11:30 AM	11:30 AM

Comparision	Accumulated Time (hr)	Power Consumption (kWh)	Hourly Power Consumption (kWh)	Saving Rate
Without SAVING SYSTEM	158.03	104.70	0.663	49.17%
With SAVING SYSTEM	152.88	51.50	0.337	



SIGNED ON BEHALF OF CUSTOMER



Date 28 Feb., 2008

SIGNATURE & COMPANY STAMP

SIGNED ON BEHALF OF POWERTECHNIC (HONG KONG) LTD

Date 29 March, 2008

SIGNATURE & COMPANY STAMP